



LAKE DON PEDRO COMMUNITY SERVICES DISTRICT

OPERATIONS MANAGER REPORT

Board of Directors Meeting
Monday, April 18th 2016

- 1. Treatment Plant:** Daily operations and maintenance of process analysis equipment is ongoing along with Jose weed eating and spraying most of treatment plant grounds. The plant continues to operate well with our ground water sources. In the very near future we will begin using the lake water again in an attempt to let our wells shut down and recover before the hot summer months arrive and to be able to utilize our lake water as it is still available.
- 2. Distribution System:** The system leaks are still down tremendously. Since our last board meeting we have had only 4 known or reported leaks. I do expect our numbers of leaks to start rising in the coming hotter months as I have seen this happen in my years with the district. As the weather gets hotter the characteristics of the ground, water, piping and demand on the system changes resulting in a higher number of service line failures.

We are still in the process of pump and motor maintenance at our tank sites and booster stations along with weed eating and grounds maintenance at those sites. Weed eating and hydrant maintenance has also begun in preparation of the fire season.

- 3. Intake:** As mentioned in my last report, intake has and will continue to take a majority of our time with moving and securing our barge as the water levels fluctuate. For most of the last 2 weeks, our staff has been removing the extensions of piping off of the lake and moving the electrical line. At this point we have removed close to 300ft of piping leaving us with just a day or two of work to remove the remaining 100 or so feet of piping.

Randy Gilgo

.
Randy Gilgo
Water Operations Manager/Chief Operator
Lake Don Pedro C.S.D.